



ASSEMBLY INSTRUCTIONS FOR YOUR WILLIAM MINI SCONCE

IMPORTANT SAFETY INSTRUCTIONS:

- * These instructions are provided for your safety. It's important that all safety instructions are read before beginning installation of fixture.
- * We **STRONGLY** recommend installation by a licensed electrician.
- * Turn off power at switch before replacing bulb, making sure fixture has sufficient time to cool down.
- * Do not connect the electricity until lamp is fully assembled.
- * This fixture is UL rated for dry location.

DIRECT WIRE ASSEMBLY INSTRUCTIONS:

1. SHUT OFF MAIN ELECTRICAL SUPPLY FROM THE MAIN FUSE BOX/CIRCUIT BREAKER. IT IS RECOMMENDED THAT A LICENSED ELECTRICIAN INSTALL THIS FIXTURE.
2. Remove mounting plate (A) from back plate (D) by removing screws (C). Lay screws (C) to the side.
3. Carefully pull the wiring from wall outlet box. Guide wires through the center hole in mounting plate (B).
4. Affix mounting plate (A) to wall outlet box with mounting screws (B) provided.
5. Lift fixture to mounting plate (A) and make proper electrical connections described in steps 6-8.
A LICENSED ELECTRICIAN IS RECOMMENDED.
6. Connect ground (green or silver in color) wire from fixture to ground wire in the outlet box. Fasten wires together with wire nut (E) and tightly wrap the connection with electrical tape.
7. Attach hot wire from fixture (black in color or smooth side of wire) to hot wire from outlet box. Fasten wires together with wire nut (E) and tightly wrap connection with electrical tape.
8. Attach neutral wire from fixture (white in color or ribbed side of wire) to neutral wire from outlet box. Fasten wires together with wire nut (E) and tightly wrap connection with electrical tape.
9. Carefully push wire connections back into wall outlet box. Slide back plate (D) over mounting plate (A).
10. Thread screws (C) into holes on sides of the back plate (D) to secure the fixture to the mounting surface.
11. Attached the shade (F) onto the socket (G).
12. Insert one 60W Max (incandescents) or 13W Max LED bulb into socket.
13. Reconnect main electrical supply at the fuse box/circuit breaker and test the fixture.

