

GENERAL PRODUCT INFORMATION:



This product is suitable for damp locations.

This product can be dimmed with a low-voltage electronic dimmer.

This instruction shows a typical installation.



CAUTION - RISK OF FIRE


This product must be installed in accordance with the applicable installation code by a person familiar with the construction and operation of the product and the hazards involved.

Use minimum 90°c supply conductors.


Note: Multiple fixtures may be interconnected at any distance apart in accordance with NEC specifications.

SAVE THESE INSTRUCTIONS!


Install the Fixture




- 1 Place and level the unit in the desired position.
- 2 Mark the two points under the cabinet through the mounting holes.




3 Secure the fixture with the provided mounting screws.



- 4 Push the two buttons back and swing open the cover.
- **5** Remove a knock out from the desired connection location



- 6 Install one of the provided conduit connectors.
- Feed the flexible conduit and the power lines into the fixture and secure it by tightening down the screws on the conduit connector.



- 8 Connect the white fixture wire to the neutral power line with a wire nut.
- 9 Connect the black fixture wire to the hot power line with a wire nut.
- Connect the fixture to a suitable ground in accordance with local electrical code.
- For models with an occupancy sensor: see included manufacturer's instruction for adjusting the settings and additional information.
- 12 Properly place the wires and wire nut connections into the fixture.
- 13 Close the cover and slide the two buttons to lock it in place.

TECH LIGHTING°

7400 Linder Ave, Skokie, IL 60077 847.410.4400

www.techlighting.com

© 2014 Tech Lighting, L.L.C. All rights reserved. The "Tech Lighting" graphic is a registered trademark of Tech Lighting, L.L.C. Tech Lighting reserves the right to change specifications for product improvements without notification.

A Generation Brands Company