Castor 17 Flush Mount

700FMCST17_ | 1.0

TL TECH LIGHTING®

FLUSH

GENERAL PRODUCT INFORMATION:

cETLus
LISTED
Intertek

These fixtures are intended to be installed utilizing NEC compliant junction boxes.

This product is suitable for damp locations.

This product can be dimmed with most ELV, TRIAC, or 0-10V dimmers.

This instruction shows a typical installation.

CAUTION - RISK OF FIRE

This product must be installed in accordance with the applicable installation code by a person familiar with the construction and operation of the product and the hazards involved.

Use minimum 90°C supply conductors.

SAVE THESE INSTRUCTIONS!

TL TECH LIGHTING®

VISUAL COMFORT & CO.

Install the Fixture

1. Separate the mounting plate from the fixture by removing the fixture screws with the provided Allen wrench.

2. Connect the fixture to a suitable ground in accordance with local electrical codes.

3. Connect the white input driver wire to the neutral power line with a wire nut.

4. Connect the black input driver wire to the hot power line with a wire nut.

5. Properly place the driver and wire nut connections into the junction box, and install the mounting plate to the junction box using #8-32 screws.

6. Drill appropriate sized holes through the holes on the mounting plate. Screw the anchor screws with washers into the holes to fully secure the mounting plate.

7. Connect the negative (-) fixture wire to the negative (-) output driver wire with a wire nut.

8. Connect the positive (+) fixture wire to the positive (+) output driver wire with a wire nut.

9. Properly place the wires and wire nut connections into the junction box, then install the fixture assembly onto the mounting plate with the fixture screws using the provided Allen wrench.