## **Ebell Wall**

## 700WSEBL, KWWS10727, KWWS10827

11

# Visual Comfort & Co.

#### MODERN COLLECTION

#### GENERAL PRODUCT INFORMATION:

These fixtures are intended to be installed utilizing NEC compliant junction boxes.



This product is safety listed for damp locations.

Dimmable with most LED compatible ELV, TRIAC and 0-10V dimmers.

Mounts vertically only. Up and downlight.


This instruction shows a typical installation.

### CAUTION - RISK OF FIRE

This product must be installed in accordance with the applicable installation code by a person familiar with the construction and operation of the product and the hazards involved.

Use minimum 90°C supply conductors.


**SAVE THESE INSTRUCTIONS!** 



VISUAL COMFORT & CO.

7400 Linder Ave., Skokie, IL 60077 T 847.410.4400 | F 847.410.4500 www.visualcomfort.com

## **Install the Fixture**



- 1 With the provided Allen wrench, loosen (do not remove) the set screw on the fixture base.
- 2 Remove the mounting plate from the fixture base
- 3 Connect the negative (-) fixture wire to the negative (-) driver output wire with a wire nut.
- 4 Connect the positive (+) fixture wire to the positive (+) driver output wire with a wire nut.
- 5 Connect the fixture to a suitable ground in accordance with local electrical codes.
- 6 Connect the white input driver wire to the neutral power line with a wire nut.
- 7 Connect the black input driver wire to the hot power line with a wire nut.
- **8** For 0-10V dimming, use the purple and gray/pink wires to connect to a compatible dimmer. If not using 0-10V dimming, make sure to cap off these wires.
- Properly place the driver, all wires, and wire nut connections into the junction box and install the mounting plate to the junction box with the two #8-32 screws provided.
- 10 Mount the fixture base onto the mounting plate, and secure it in place by tightening the set screws using the provided Allen wrench.